



Inspection and Technical Services
Municipal Relations
508-401 York Ave
Winnipeg, Manitoba Canada R3C 0P8
T 204-945-3373 F 204-948-2089
www.firecomm.gov.mb.ca/itsm_main

1/28/2021

Mister CEN Consulting Inc.
BOX 488
Montague, PEI C0A 1R0
CA

Dear Miller West

Re: Reciprocal CRN Registration in Manitoba

Your application indicates that a CRN has been received in another Canadian Jurisdiction, and therefore your CRN has been registered in Manitoba as follows:

File Number: 74-R1241
CRN: 0E1965.74
Scope: As listed in CRN registration list
Manufacturer: Aalberts Integrated Piping Systems APAC Inc.
Expiry Date: 18/Dec/30

Please find attached invoice for registration.

As indicated by the Regulatory Reconciliation and Cooperation Table and the Reconciliation Agreement for the Canadian Registration Number (CRN) for Pressure Equipment, a CRN issued in any Canadian Jurisdiction will be accepted for use in Manitoba.

In accordance with Steam and Pressure Plants Regulation and CSA B51, it is the manufacturer's responsibility to file a Manufacturers Data Report, including partial data reports, with our office, prior to shipping pressure equipment to Manitoba.

Please contact qasupport@gov.mb.ca for any questions or concerns.

Inspection and Technical Services
Municipal Relations
508 - 401 York Avenue, Winnipeg Manitoba R3C 0P8
T (204) 945-3373 | F (204) 948-2089

CRN Registration

Oct. 30, 2020

Shurjoint Grooved Components are to be registered (Category E - Strainers)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
726 Y-Strainer	2, 2½, 3, 4, 5, 6	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-726 166 160a 160c AS-7705B
	8	100		H105 AS-7771 H108b 68
	10, 12, 14, 16	75		G15a G15b 7705TB S819001
C726 Y-Strainer for Copper Tubing (CTS)	2, 2½, 3, 4, 6	150	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-C726 1CH 1C8 1C6 GC4 7705TB S819001
SS-726 Stainless Steel Y-Strainer	2½, 3, 4, 6	300	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SS726 1SP 1SQ As-SS8 G15a STB